

Number	17-002831-PR05 (NW-A01-02-en-01)
Owner	REHAU AG + Co. Verwaltung Erlangen Ytterbium 4 91058 Erlangen-Eltersdorf Germany
Product	Drop-down top-hung window
Designation	Shipping name: Nordic Design Plus
Details	Manufacturer REHAU AG + Co., Verwaltung Erlangen - Erlangen-Eltersdorf; Material RAU-FIPRO; Type of opening Drop-down top-hung; Opening direction Outwards; Overall dimensions (W x H) 1230 mm x 1510 mm
Special features	

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: E1500


Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
e.g. DIN EN

Test report: 17-002831-PR05 PB-A01-02-de-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

15.11.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Florian Walter
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 7E5-CA8C1